Depth to Water Below Top of Casing (BTOC, measured in feet)							
2023 Data	Well #1 (540/600')	Well #2 (93/100')	Well #3 (107/123')	Monthly Rainfall	CTGCD Drought	Water Pumped	
Stage II Drought Threshold	30	30	55	(inches)	Stage	(K Gals)	
Stage III Drought Threshold	60	60	70	(otage	(11 0 0.10)	Remarks/Comments
January (1/20/23)	37.0	60.0	69.0	1.43	Critical	584.0	10 hours of recharge.
February (2/21/23)	25.8	15.2	68.4	2.08	Critical	570.0	4 hours of recharge.
March (3/20/23)	25.9	13.6	69.5	1.83	Critical	609.0	Cease pumping from #3
April (4/14/23)	29.8	18.3	65.0		Critical		
April (4/28/23)	28.8	19.7	60.9	3.20	Critical	554.0	No pumping Well #3
May (5/12/23)	26.2	17.6	55.7	5.05	Critical	609.0	No pumping Well #3
June (6/20/23)	31.8	16.4	39.8	1.38	Critical	853.0	No pumping Well #3
July (7/17/23)	42.4	21.7	54.9	0.10	Critical	703.0	Well #3 pumping
August (8/18/23)	68.2	37.0	65.9	0.27	Critical	1,044.0	
September (9/19/23)	55.2	59.9	69.9	3.70	Critical	680.0	
October (10/23/23)	57.6	65.9	73.2	4.06	Critical	656.0	
November (11/16/23)	33.0	18.6	72.4	1.61	Critical	623.0	
December (12/13/23)	35.3	19.0	73.0	1.22	Critical	548.0	
			Annual Total	25.93		8,033.0	