

Depth to Water Below Top of Casing (BTOC, measured in feet)							
2024 Data	Well #1 (540/600')	Well #2 (93/100')	Well #3 (107/123')	Monthly Rainfall (inches)	CTGCD Drought Stage	Water Pumped (K Gals)	Remarks/Comments
Stage II Drought Threshold	30	30	55				
Stage III Drought Threshold	60	60	70				
January (01/14/24)	31.1	15.0	73.5	2.89	Critical	671.0	
February (02/13/24)	24.8	10.9	73.6	1.48	Critical	530.0	
March (03/15/24)	26.4	14.1	73.9	1.28	Critical	616.0	
April (04/16/24)	31.7	16.0	73.7	2.80	Critical	661.0	
May (05/18/24)	24.0	11.6	71.8	7.55	Critical	545.0	
June (6/17/24)	25.8	13.6	72.4	1.59	Severe	736.0	
July (07/14/24)	33.9	14.0	75.6	4.77	Severe	790.0	Well #2 elec. malfunction
August 08/16/24)	125.0	17.4	80.1	1.24	Severe	891.0	Well #2 elec. malfunction
September (09/10/24)	29.7	16.1	83.6	2.73	Severe	840.0	Well #2 pump & motor replaced
October (10/17/24)	40.2	28.1	91.3	0.01	Severe	813.0	
November (11/16/24)	51.7	66.2	93.6	0.70	Severe	678.0	
December (12/16/24)	89.9	73.7	97.3	0.83	Severe	756.0	
			Annual Total	27.87		8,527.0	